


# IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761 • Phone (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



## CERTIFICATE OF LISTING



IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

*Issued To:*

### OMEGA FLEX INC.

451 CREAMERY WAY EXTON, PA 19341 , United States

*Product:*

### Gas Piping Corrugated Stainless Steel Tubing System

*Products are in compliance with the following code(s):*

**Uniform Plumbing Code (UPC®)  
National Plumbing Code of Canada**

*Products are in compliance with the following standard(s)*

**ANSI LC 1-2019/CSA 6.26-19**

**File Number:** 3682

**Effective Date:** August 2019

**Void After:** August 2024\*

  
Chairman, Product Certification Committee




  
Chief Technical Service Officer

\*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING



Issued To: OMEGA FLEX INC.

Effective Date: August 2019

File Number: 3682

Product: Gas Piping Corrugated Stainless Steel Tubing System

Void After: August 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

### Identification:

Each component of piping system shall bear permanent markings which include the manufacturer's name, trademark or symbol, part number, symbol of the organization making the test for compliance with ANSI LC 1/CSA 6.26. The tubing shall also bear a permanent marking of the rated pressure, the equivalent hydraulic diameter (EHD), the words "FUEL GAS" (GAZ COMBUSTIBLE) and the words "Arc-Resistant" or "AR". These markings shall appear on tubing at not less than 24-inch interval. In addition, each component supplied by the manufacturer shall bear a separate date code marking in accordance with ANSI LC 1/CSA 6.26(-year). Each fitting shall bear the fitting size code. The product shall also bear the cUPC® certification mark.


### Characteristics:

Interior fuel gas piping systems, using corrugated stainless steel tubing, to be used in installation in residential or commercial buildings. Components include tubing, fittings, manifolds and striker plates. May be used in conjunction with other approved fuel gas piping materials. May be used for fuel gas at maximum actual operating pressure not exceeding 25 psig. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING



Issued To: OMEGA FLEX INC.

Effective Date: August 2019

File Number: 3682

Product: Gas Piping Corrugated Stainless Steel Tubing System

Void After: August 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

### Models

**Note: Products meet the applicable portions of CSA B149.1.**

#### TracPipe FLEXIBLE GAS PIPING

##### TUBING:


| Model Number | Description |
|--------------|-------------|
| FGP-CS-375   | 3/8"        |
| FGP-CS-500   | 1/2"        |
| FGP-CS-750   | 3/4"        |
| FGP-CS-1000  | 1"          |
| FGP-CS-1250  | 1-1/4"      |
| FGP-CS-1500  | 1-1/2"      |
| FGP-CS-2000  | 2"          |
| FGP-SS4-375  | 3/8"        |
| FGP-SS4-500  | 1/2"        |
| FGP-SS4-750  | 3/4"        |
| FGP-SS4-1000 | 1"          |
| FGP-SS4-1250 | 1-1/4"      |
| FGP-SS4-1500 | 1-1/2"      |
| FGP-SS4-2000 | 2"          |

##### FITTINGS:

| Model Number   | Description                |
|----------------|----------------------------|
| FGP-1X-size    | Meter Stub-out             |
| FGP-ASP        | Appliance Stub-out         |
| FGP-BF90V-size | 90 Degree Flange w/Valve   |
| FGP-BFF-size   | Brass Flange Fitting       |
| FGP-CPLG-size  | Coupling                   |
| FGP-ELLB-size  | Elbow Brass Flange Fitting |

# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING



Issued To: OMEGA FLEX INC.

Effective Date: August 2019

File Number: 3682

Product: Gas Piping Corrugated Stainless Steel Tubing System

Void After: August 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

| Model Number     | Description                        |
|------------------|------------------------------------|
| FGP-ELL-size     | Elbow Flange                       |
| FGP-FF-size      | Flange Fitting                     |
| FGP-FSTF-size    | Female Straight Coupling           |
| FGP-FST-size     | Straight Fitting                   |
| FGP-FTP          | Fireplace Stub-out                 |
| FGP-MI-XX-size   | Manifolds                          |
| FGP-MT-size      | Meter Termination                  |
| FGP-RST-size     | Reducing Fitting                   |
| FGP-RT-size      | Reducer Tee                        |
| FGP-SMF-500      | One Piece Construction End Fitting |
| FGP-TF-1250-size | Tee-TracPipe 1-1/4"                |
| FGP-TF-1500-size | Tee-TracPipe 1-1/2"                |
| FGP-TF-2000-size | Tee-TracPipe 2"                    |
| FGP-TF-size      | Tee-TracPipe                       |
| FGP-TM90V-size   | 90 Degree Termination w/Valve      |
| FGP-TM-size      | Termination Mount                  |
| FGP-T-size       | Tee-Pipe                           |
| FGP-WBTM-size    | Metal Wall Box w/Valve             |
| FGP-WBT-size     | Wall Box w/Valve                   |
| FGP-KVB Size     | Fitting Assembly                   |